

**CITY of  
SPRINGFIELD**



May 8, 1990

Mr. Dan Hoy, Maintenance Manager  
Bass Pro Shops, Inc.  
1935 South Campbell  
Springfield, Missouri 65898

Dear Mr. Hoy:

This letter will confirm our conversation at your facility on this date concerning the discharge of chemicals to the sanitary sewer and sewer billing for the salt water and pool filter room.

This office appreciates the tour conducted by you and Ms. Marla Leighton of the photographic dark room. It appears the spent chemicals generated by this operation are acceptable for discharge to the sanitary sewer. The individual quantities of one quart or less per month will not cause problems with treatment processes and although no MSDS sheets were available the contents listed on the packages do not appear to be a health hazard for sewer workers. Bass Pro should dispose of the chemicals using directions obtained from the manufacturer.

The disposal of any type of liquid in the Springfield Landfill is prohibited by it's operating permit and should be avoided.

The review of the south filter room indicates hour meters on the pumps in the sump will measure the discharge to the sanitary sewer for billing purposes. A pump curve or other appropriate document will be needed to calculate the actual discharge volume from the hour readings. When the meters are installed include the separate reading on your monthly well water meter reading sheet.

If you have any questions please feel free to call 864-1924.

Yours truly,

Stephen Short  
Water Pollution Control Inspector

cc Robert Schaefer, P.E., Supt. of Sanitary Services  
Randy Lyman, Sewer Surveillance and Billing Supervisor  
file (2)

1935 S. Campbell